Department of Licensing and Regulatory Affairs, Bureau of Fire Services, Storage Tank Division P.O. Box 30033, Lansing, MI 48909 AUTOMOTIVE SERVICE STATION CHECKLIST

	FIONS: The Hazardous Materials Storage rict file and one for the Main Office file. All							one to be	retair	ned
FACILITY		50,000 01	ian b	o complet	od incorting r	WAY WHO TO HO	FACILITY ID NUMBER			
CONTACT	PERSON ON SITE	,	Area (Code & T	elephone Nur	mber	FACILITY TYPE			
							Public	Private		
EMAIL AD	DRESS OF RESPONSIBLE PERSON						1			
			OPE	ERATION	SECTION					
SECTION			VIOI	PASS	SECTION	Diantarrana	of of acciptuation	CODE S63	VIO P	ASS
6.7	Emergency power disconnect	S93			280.22h		splay proof of registration			
9.2.5.2	Fire extinguisher, 100 feet	S59			280.22a		n submitted 30 days	S62		
9.4.5	Dispenser in view and communicate	S92			280.22a		gistered & fees paid	S61	-	
280.93	Financial Responsibility	U92			6.2.1	Electric cer		U70		
							ous violation	S50		
280.13	Have Certified A – B operator	U103	-B-C	OPERAT	OR SECTION 280.13d		erator present	U107		
280.13a	Registration submitted for A-B	U106			280.13d		ined for conditions	U119		
280.13b	New owners cert. 30 days of purchase	U114			280.13b		lass C trained Emp.	U112	-	
280.13b	Must have Class B before operating	U114		 	280.13c		nspections performed	U104		
200.100	muct have class 2 before operating	0111			280.13c		rt Signed by B Operator	U105		
				RECO		пор. поро	Troighted by B Operator	0103		İ
280.34	Maintenance records	S65			280.34	Release de	etection records	S67		
280.44a	Line leak detector tested	U95			280.31b	C/P tested 6 months & 3 years		U30		
280.41b	Line tightness test – pressure	U88		 	280.31c		current, 60 day log	S35		
280.41b	·	U89			280.34	Cathodic protection records*		S64	-	
	Line test - suction every 3 years					,		364		
6.3.9.1.	Emergency valve tested	S94			*NOTE-	Includes CP upgrade testing results				
280.34	General record keeping violation	S60								
			REL	EASE D	ETECTION					
280.40	Release detection for tanks	U71			280.43e	Vapor mon	itoring (approval req.)	U73		
280.43a	Inventory control (not stand alone)	S42			280.43f	Groundwat	er monitoring	U74		
280.43b	Manual gauging (less then 550)	S43			280.43g	Interstitial r	monitoring (stand alone)	U75		
280.43c	Tank tightness testing	S44			280.43h	S.I.R (star	id alone)	U93		
280.43d	Automatic tank gauging	U72			280.43h	Other		S49		
<u> </u>	1		1		L	1		1		
COMMEN	IS									

Department of Licensing and Regulatory Affairs, Bureau of Fire Services, Storage Tank Division P.O. Box 30033, Lansing, MI 48909 AUTOMOTIVE SERVICE STATION CHECKLIST

DISPENSER SECTION

6.2.3. Dispenser location (10 feet) 6.3.4. Dispenser protected; damage/secured 9.2.5.4. No smoking, stop motor, unapproved cont., Remain out of vehicle in view 6.6.6. Splash guard on nozzle 6.5.1 Dispenser Hose 18 feet or less 6.3.3 Pump only operate with handle remove/manually actuated. S12 UNDERGROUND TANK SECTION 280.20 Spill containment - Testing request 280.20c Spill containment - Inoperative U101 6.3.4.1. Containment 6.3.9. Emergency vi 6.6.1. Automatic sel 6.6.1. Automatic sel 6.3.5. Class I Disp. 6.2.1 All vehicles fu of dispensing 2.3.3.4. Location of fill 3.7.2.1. Vent pipes, 12 3.7.2.4. Vent pipes, C	If-closing nozzle / date S19 structions posted S25 20 feet from fuel oil S16 ueling are on premises S20	
6.3.4. Dispenser protected; damage/secured S13 9.2.5.4. No smoking, stop motor, unapproved cont., Remain out of vehicle in view 6.6.6. Splash guard on nozzle S91 6.3.5. Class I Disp. 6.3.3 Pump only operate with handle remove/manually actuated. UNDERGROUND TANK SECTION 280.20 Tank miscellaneous violation S30 280.20 Spill containment - Testing request U51 280.20c Spill containment - Inoperative U101 280.3.3 Dispenser Plose 18 feet or less S14 6.3.5. Class I Disp. 6.2.1 All vehicles further of dispensing singular plants for the control of fill singular plants for the control of the control o	alve installed S18 If-closing nozzle / date S19 structions posted S25 20 feet from fuel oil S16 ueling are on premises S20 facility. I pipe & identified U46	
9.2.5.4. No smoking, stop motor, unapproved cont., Remain out of vehicle in view 6.6.6. Splash guard on nozzle 6.5.1 Dispenser Hose 18 feet or less 6.3.3 Pump only operate with handle remove/manually actuated. 9.4.4. Operating ins 6.3.5. Class I Disp. 6.2.1 All vehicles for of dispensing UNDERGROUND TANK SECTION 280.20 Tank miscellaneous violation 280.20 Spill containment - Testing request 280.20 Spill containment - Testing request 280.20 Spill containment - Inoperative 280.20 Spill containment - Inoperative 280.20 Tight fitting hose connection (1,000 & U44 280.20 Spill containment - Inoperative 380.20 Spill containment - Inoperative	If-closing nozzle / date S19 structions posted S25 20 feet from fuel oil S16 ueling are on premises S20 facility. I pipe & identified U46	
cont., Remain out of vehicle in view 6.6.6. Splash guard on nozzle 6.5.1 Dispenser Hose 18 feet or less 6.3.3 Pump only operate with handle remove/manually actuated. CUNDERGROUND TANK SECTION 280.20 Tank miscellaneous violation 280.20 Spill containment - Testing request 280.20 Spill containment - Inoperative 280.20 Spill containment - Inoperative 280.20 Tight fitting hose connection (1,000 & U44 Current 9.4.4. Operating ins 6.3.5. Class I Disp. 6.2.1 All vehicles furth of dispensing 2.3.3.4. Location of fill 3.7.2.1. Vent pipes, 12 3.7.2.4. Vent pipes, 12 3.7.2.4. Drop tube: 6 in view 1.4. Operating ins 1.5. Class I Disp. 1.5. Class I Dis	tructions posted S25 20 feet from fuel oil S16 ueling are on premises S20 facility.	
6.6.6. Splash guard on nozzle 6.5.1 Dispenser Hose 18 feet or less 6.3.3 Pump only operate with handle remove/manually actuated. S12 UNDERGROUND TANK SECTION 280.20 Tank miscellaneous violation 280.20 Spill containment - Testing request 280.20 Spill containment - Inoperative 280.20 Spill containment - Inoperative 280.20 Spill containment - Inoperative 280.20 Tight fitting hose connection (1,000 & U44 S12 9.4.4. Operating ins 6.3.5. Class I Disp. 6.2.1 All vehicles further of dispensing 1.2.2.1 All vehicles further of dispensing 1.2.2.3.3.4. Location of fill 1.2.2.3.3.4. Location of fill 1.2.2.3.3.4. Vent pipes, 1.2.2.3.3.4. Drop tube: 6 in 1	20 feet from fuel oil S16 ueling are on premises S20 facility. I pipe & identified U46	
6.5.1 Dispenser Hose 18 feet or less S14 6.3.5. Class I Disp. 6.3.3 Pump only operate with handle remove/manually actuated. S12 S20.20 Tank miscellaneous violation S30 2.3.3.4. Location of fill 280.20c Spill containment - Testing request U51 3.7.2.1. Vent pipes, 12 280.20c Spill containment - Inoperative U101 3.7.2.4. Vent pipes, C2.3.3.4. Drop tube: 6 i	20 feet from fuel oil S16 ueling are on premises S20 facility. I pipe & identified U46	
6.3.3 Pump only operate with handle remove/manually actuated. S12 UNDERGROUND TANK SECTION 280.20 Tank miscellaneous violation 280.20c Spill containment - Testing request 280.20c Spill containment - Inoperative 2.3.3.4.3. Tight fitting hose connection (1,000 & U44 S12 6.2.1 All vehicles function of dispensing 2.3.3.4. Location of fill 3.7.2.1. Vent pipes, 1: 3.7.2.4. Vent pipes, C 2.3.3.4. Drop tube: 6 i	facility. I pipe & identified U46	
remove/manually actuated. UNDERGROUND TANK SECTION 280.20 Tank miscellaneous violation S30 2.3.3.4. Location of fill 3.7.2.1. Vent pipes, 1.2 280.20c Spill containment - Inoperative U101 3.7.2.4. Vent pipes, C 2.3.3.4.3. Tight fitting hose connection (1,000 & U44 2.3.3.4. Drop tube: 6 i	facility. I pipe & identified U46	
UNDERGROUND TANK SECTION 280.20 Tank miscellaneous violation S30 2.3.3.4. Location of fill 280.20c Spill containment - Testing request U51 3.7.2.1. Vent pipes, 12 280.20c Spill containment - Inoperative U101 3.7.2.4. Vent pipes, C 2.3.3.4.3. Tight fitting hose connection (1,000 & U44 2.3.3.4. Drop tube: 6 i	I pipe & identified U46	<u> </u>
280.20Tank miscellaneous violationS302.3.3.4.Location of fill280.20cSpill containment - Testing requestU513.7.2.1.Vent pipes, 1:280.20cSpill containment - InoperativeU1013.7.2.4.Vent pipes, C2.3.3.4.3.Tight fitting hose connection (1,000 & U44U442.3.3.4.Drop tube: 6 i	· ·	
280.20c Spill containment - Testing request U51 3.7.2.1. Vent pipes, 12 3.7.2.4. Vent pipes, C2.3.3.4.3. Tight fitting hose connection (1,000 & U44 2.3.3.4. Drop tube: 6 i	· ·	
280.20c Spill containment - Inoperative U101 3.7.2.4. Vent pipes, C 2.3.3.4.3. Tight fitting hose connection (1,000 & U44 2.3.3.4. Drop tube: 6 i	2 feet Class I liquid U32	
2.3.3.4.3. Tight fitting hose connection (1,000 & U44 2.3.3.4. Drop tube: 6 i		
	class II & IIIA U33	
up)	inches of tank bottom U45	
280.20c Overfill prevention - Testing request U52 2.2.3.1 Tanks proper	design & construction U12	1
280.20C Overfill prevention - Inoperative U102 280.20 Cathodic prot	tection for tanks U29	1
PIPING SECTION		
280.40 Release detection for piping U71 280.44c Interstitial (mo	onthly) monitoring U94	
280.44a Line leak detector installed U76 3.2.2. Pipe leaks	U62	
280.20 Cathodic protection for piping U29 280.20b Piping shall b	e approved material U61	
ank Construction Piping Material ping; Suction Pressure Sump Sensors: Yes No Tank Monitor M OMMENTS		